



UK - Declaration of Conformity

Manufacturer: Bender GmbH & Co. KG

declare under our sole responsibility that the product

Product name: Insulation monitoring device iso410_415_420 (see annex)

to which this declaration relates, is in conformity with the following UK legislations.


Legislations:	RoHS Regulations 2012	S.I. 2012/3032
	Radio Equipment Regulations 2017	S.I. 2017/1206

The assessment of this product has been based on the following standards:


Applied standards :

EN 50364	:2010
EN 61326-2-4	:2013
EN 61557-1	:2007
EN 61557-8	:2015
EN IEC 63000	:2018
ETSI EN 300 330	V2.1.1 :2017-02
ETSI EN 301 489-1	V2.2.3 (2019-11)
ETSI EN 301 489-3	V2.3.2 :2023-01

Gruenberg, 28.06.2023



(H. Nowicki, CSO)



(i.V. J. Schäfer, Quality Manager)

Remark:

The annexes are part of this UK declaration.
Limitation of standards are marked with an asterisk (*) in the attached type list.

Annex - Typelist of UKCA-declaration iso410_415_420

Product group	Art.-no.	Device type
iso415	B71602000	iso415R-24 3(N)AC, AC 0-415V/DC 0-400V
iso415	B71603000	iso415R-2 3(N)AC, AC, DC 100...240 V